

Specifications

Digital Conversion Module

CSD-892-73

Spec. No. EN382892-73A

1/8

1. General

This instrument is the digital conversion module for strain gage applied transducers which adopt the DIN mounting type and in suitable with built-in control panel.

2. Specifications

2-1. Specifications for analog

- Bridge power supply DC5 V \pm 0.25 V within 60 mA, with sensing
- Applicable transducers Up to 4 pieces of strain gage applied transducers(350 ohm) can be connectable.
- Input sensitivity 0.15 μ V/d or more (d=minimum scale)
* 0.2 μ V/d (In case of applying CE conformity standard.)
- Input range -3.1 mV/V to 3.1 mV/V
- Zero adjustment range ± 2.5 mV/V
- Non-Linearity 0.01 %F.S.
- Temperature coefficient
Zero point ± 0.2 μ V/ $^{\circ}$ C
(When the calibration is made at 0.2 μ V/d or more of the input sensitivity.)
Sensitivity ± 0.0015 %F.S./ $^{\circ}$ C
(When the calibration is made at 0.2 μ V/d or more of the input sensitivity.)
- Input noise ± 0.2 μ Vp-p or less
(At the default setting of analog filter, digital filter and stabilization filter.)
- Analog filter Approx. 4Hz (Changeable to 2Hz, 6Hz, 8Hz, 10Hz)
- A/D sampling 500 times/s (Changeable to 250 times/s, 100 times/s, 50 times/s.)
- A/D internal resolution 24 bits

2-2. Specification for digital

- Main display (Load display)
 - Display range $-99\ 999$ to $99\ 999$
 - Display increment 1 (Changeable to 2, 5, 10, 20, 50)
 - Display unit FSTN liquid crystal (With amber color LED back light.)
 - Over display “-OL” display at minus over, “OL” display at plus over
 - AD value over display “-OVF” display at minus over, “OVF” display at plus over
- Condition display ZERO, SPAN, mV/V, STABLE, TARE, GROSS, NET, CZ, LOCK, HOLD, ERROR
- Display rate 2 times/s
- Judgement display OUT 1, 2, 3, 4, 5
- Decimal point display No display, 10^1 , 10^2 , 10^3 and 10^4 changeable.
- Unit display No display, g, kg, t, N, kN, lb, Pa, kPa or MPa changeable.

Specifications

CSD-892-73

Spec. No. EN382892-73A

2/8

2-3. Specifications for setting

- Internal setting value

EEPROM

Calibration data, the data that relates to calibration and ComParator set value

SRAM

Zero set data, Zero tracking data, and Tare data.

(The backup function is not provided in SRAM. You can change the stored place of Zero set data, Zero tracking data and Tare data to EEPROM by the function setting.)

2-4. Function of front panel key switch

FUNC

Shifts to Function / Shifts to Calibration setting mode.

(By pushing 2 seconds or more)

CAL-Z/◀

Shifts to ZERO calibration mode of a simple calibration.

(By pushing 2 seconds or more)

/Shifts to calibration lock mode of a simple calibration.

(By pushing 2 seconds or more CAL-Z/◀ and CAL-S/▲)

/ Carry up the setting value.

CAL-S/▲

Shifts to SPAN calibration mode of a simple calibration.

(By pushing 2 seconds or more)

/ Set value increment.

F / ENTER

Selects from Non, Hold, Zero set, Zero clear, Tare, Tare clear, Changeover the display for net value or gross value, Check to CC-Link station number

/Registration of set value

Specifications


CSD-892-73

Spec. No. EN382892-73A

3/8

2-5 .External control function

- Input signals of external control 9 points
 - 3 functions in the following can be arbitrarily selected.
 - OFF
 - Zero set
 - Zero clear
 - Tare
 - Tare clear
 - Hold
 - Changeover the display for net value or gross value
 - * Above are pulse input, and effective only once at the pulse width of 50 ms or more.
 - Hold
 - * Above are level input, and effective during the input of short for 50 ms or more.
 - Display of NET (With ON, the net weight is displayed when the Gross weight is shown.)
 - * Above are level input, and effective during the input of short for 50 ms or more.
- Equivalent circuit of the external control input section



Specifications


CSD-892-73

Spec. No. EN382892-73A

4/8

- External control output signals
5 functions in the following can be arbitrarily selected.
 - OFF
 - RUN
 - Stable
 - During canceling the Tare weight
 - Display of gross
 - Display of net
 - Center zero
 - During the hold
 - Error, Abnormal weight
 - Z-Band
 - OK (S0),
 - Big flow (S1)
 - Middle flow (S2)
 - Small flow (S3)
 - Over (S4)
 - Under
 - Full

- Equivalent circuit of external control output



Rated open collector $V_{CE} = DC35 V_{max}$, $I_C = DC50 mA_{max}$

* COM.1 and COM.2 are connected in the instrument.

2-6. Comparator function

- | | |
|--------------------------------------|--|
| • Set value | —99 999 to 99 999 |
| • Numbers of setting | 5 points of S0, S1, S2, S3 and S4 |
| • Set value of hysteresis data width | 0 to 99 digit |
| • Direction of hysteresis | Whichever changeable to “On delay” or “Off delay” |
| • Conversion times of comparator | Changeable to synchronous with the A/D sampling times or display late. |

Specifications

CSD-892-73

Spec. No. EN382892-73A

5/8

2-7. CC-Link interface

- Version of CC-Link : Ver.1.10
- Occupied stations Nos. : Selectable from 1, 2 or 4 stations.
- Specifications
 - Baud rate : Selectable from 156 kbps, 625 kbps, 2.5 Mbps, 5 Mbps or 10 Mbps.
 - Communication method : Poling method
 - Synchronous method : Bit synchronous method
 - Transmission route : RS-485 bus
 - Transmission format : HDLC conforming
 - Remote station : 01 to 64 when one station is occupied.
01 to 63 when two stations are occupied.
01 to 61 when four stations are occupied.
 - Connectable units : 64 units at maximum with occupied one station.
32 units at maximum with occupied two stations.
16 units at maximum with occupied four stations.
 - Connectable cable : Shielded twist pair special cable for "CC-Link"
 - Termination : Attached with 110 ohm resistance externally.
 - Status LED : Display the communication status by four (4) LEDs of "RUN", "ERR", "SD" and "RD".

• Connector configuration of CC-Link

Pin No.	Signal name	Signal name
1	DA	Signal cable at DA side
2	DB	Signal cable at DB side
3	DG	Signal cable ground
4	SLD	Shield
5	FG	Frame ground

* Suitable plug for CC-Link connector plug : MSTB 2, 5/5-ST-5, 08 ABGY AU (made by Phoenix Contact.)

* "SLD" and "FG" are connected in the instrument.

• Function

- (1) Reading out the load.
- (2) Actual load calibration.
- (3) Reading out the condition
- (4) Changing the condition
- (5) Reading out the setting of basic function, I/O, measurement operation and sequence control.
- (6) Changing the setting of basic function, I/O, measurement operation and sequence control.

* CC-Link is abbreviation of Control & Communication Link.

Specifications

CSD-892-73

Spec. No. EN382892-73A

6/8

2-8. USB interface

- Standard Comforms to USB2.0 (Can also use with the standard of USB1.1)
- Connector mini USB B type (female)
- * Please use the USB interface after installing a special driver in the host side.

2-9. Various functions

- Zero tracking Stabilize the fluctuation of the zero point in a constant condition.
- Digital filter Data is stabilized through the calculation process with the software in CPU.
- Stabilized filter The digital filter is reinforced and stabilized only when the width of the change of the load is constant.
- Digital linearize Executes the compensation of the non-linearity by the max. 3 points or less.

3. General specifications

- Operating temperature/humidity range
 - Temperature $-10\text{ }^{\circ}\text{C}$ to $50\text{ }^{\circ}\text{C}$
 - Humidity 85 %RH or less (Non condensing.)
- Stored temperature range $-20\text{ }^{\circ}\text{C}$ to $60\text{ }^{\circ}\text{C}$
- Power supply
 - Power supply voltage DC24 V (Permissible variable range DC20.4 V to DC27.6 V)
 - Power consumption Approx. 2.4W (at DC24 V)
- Outline dimensions 72 mm(W)× 96 mm(H)× 67.4 mm(D)
(excludes protruding parts)
- Weight Approx. 260 g

4. Specifications at the time of shipment

- Bridge power supply DC5 V
- Span adjustment 10 000 display at the input of 0.5 mV/V
- The minimum scale 1

5. Accessories

- Start guide (in Japanese) 1 piece
- Start guide (in English) 1 piece
- CC-Link connector 1 piece
- Short bar, between A-F and C-G
2 pieces

6. Options

6-1. EzCTS (Ez Communication Tool Software)

The PC that installs EzCTS and connects with CSD-892-73, can read and write the parameter set with CSD-892-73.

* For details, EzCTS please refer to specifications.


Specifications

CSD-892-73

Spec. No. EN382892-73A

7/8

7. Outline dimensions



Unit : mm

* It corresponds to the rail of 35 mm of din standard width.

Specifications

CSD-892-73

Spec. No. EN382892-73A

8/8

8. Conformity standard

- This instrument has suited the following standard.
EN61326 : 2006
“Electrical equipment for measurement, control and laboratory use – EMC requirements”
“Immunity test requirements for equipment intended for use in industrial locations”
* CE conformity standard is not effective in case of using optional USB interface.
The using condition to suit this standard is as follows.

8-1 .Place of installation

- Please set up in the shielded case or control panel where EMC measure are given in case of conforming EN61326 : 2006 to the standard for this instrument.

8-2 .Wiring

① About cable

- Use the shielded cable for all connections expects a power cable.

② Shield processing

- For the cable of load cell, make connection with the E terminal on the terminal board of load cell.
- For the CC-Link interface, make connection with the F.G. terminal on the CC-Link terminal board.
- Shield the CC-Link cable and the external I/O cable securely by using the conduit piping including the stored case.

8-3 .Power supply

- The power supply by which DC24V is supplied to the instrument must use the conformed product of CE standard, and set the instrument up in the same storage case.

* Specifications and Outline dimensions and so on which have printed may subject to change for the purpose of improvement without notice.