



Features:

- High efficiency 94% and low power dissipation
- 150% peak load capability
- Built-in active PFC function, PF>0.94
- Protections: Short circuit / Overload / Over voltage / Over temperature
- Cooling by free air convection
- Built-in constant current limiting circuit
- Can be installed on DIN rail TS-35/7.5 or 15
- UL 508(industrial control equipment)approved
- EN61000-6-2(EN50082-2) industrial immunity level
- Built-in DC OK relay contact
- 100% full load burn-in test
- 150% peak load capability
- 3 years warranty









SPECIFICATION

MODEL		SDR-480-24	SDR-480-48	
	DC VOLTAGE	24V	48V	
ОИТРИТ	RATED CURRENT	20A	10A	
	CURRENT RANGE	0 ~ 20A	0 ~ 10A	
	RATED POWER	480W	480W	
	PEAK CURRENT	30A	15A	
	PEAK POWER Note.6	720W (3sec.)		
	RIPPLE & NOISE (max.) Note.2	100mVp-p	120mVp-p	
	VOLTAGE ADJ. RANGE	24 ~ 28V	48 ~ 55V	
	VOLTAGE TOLERANCE Note.3	±1.2%	±1.0%	
	LINE REGULATION	±0.5%	±0.5%	
	LOAD REGULATION	±1.0%	±1.0%	
	SETUP, RISE TIME	1500ms, 150ms/230VAC 3000ms, 150ms/115VAC at full load		
	HOLD UP TIME (Typ.)	14ms/230VAC at full load		
INPUT	VOLTAGE RANGE Note.7	90 ~ 264VAC 127 ~ 370VDC		
	FREQUENCY RANGE	47 ~ 63Hz		
	POWER FACTOR (Typ.)	0.94/230VAC 0.99/115VAC at full load		
	EFFICIENCY (Typ.)	94%		
	AC CURRENT (Typ.)	5A/115VAC 2.5A/230VAC		
	INRUSH CURRENT (Typ.)	40A/115VAC 80A/230VAC		
	LEAKAGE CURRENT	<0.8mA / 240VAC		
PROTECTION		Normally works within 110 ~ 150% rated output power for more than 3 seconds and then shut down o/p voltage with auto-recovery		
	OVERLOAD	>150% rated power, constant current limiting with auto-recovery within 2 seconds and may cause to shut down if over 2 seconds		
		29 ~ 33V	56 ~ 65V	
	OVER VOLTAGE	Protection type: Shut down o/p voltage with auto-recovery or re-power on to recovery		
	OVED TEMPEDATURE	105°C ±5°C (TSW: detect on heatsink of power switch)		
	OVER TEMPERATURE	Protection type: Shut down o/p voltage, recovers automatically after temperature goes down		
FUNCTION	DC OK REALY CONTACT RATINGS (max.)	60Vdc/0.3A, 30Vdc/1A, 30Vac/0.5A resistive load		
ENVIRONMENT	WORKING TEMP. Note.5	-25 ~ +70°C (Refer to output load derating curve)		
	WORKING HUMIDITY	20 ~ 95% RH non-condensing		
	STORAGE TEMP., HUMIDITY	-40 ~ +85°C, 10 ~ 95% RH		
	TEMP. COEFFICIENT	±0.03%/°C (0~50°C)		
	VIBRATION	Component: 10 ~ 500Hz, 2G 10min./1cycle, 60min. each along X, Y, Z axes; Mounting: Compliance to IEC60068-2-6		
SAFETY & EMC (Note 4)	SAFETY STANDARDS	UL508, TUV EN60950-1 approved		
	WITHSTAND VOLTAGE	I/P-O/P:3KVAC I/P-FG:1.5KVAC O/P-FG:0.5KVAC O/P-DC OK:0.5KVAC		
	ISOLATION RESISTANCE	I/P-O/P, I/P-FG, O/P-FG:>100M Ohms / 500VDC / 25°C / 70% RH		
	EMI CONDUCTION & RADIATION	Compliance to EN55022 (CISPR22) Class B		
	HARMONIC CURRENT	Compliance to EN61000-3-2,-3		
	EMS IMMUNITY	Compliance to EN61000-4-2,3,4,5,6,8,11, ENV50204, EN55024, EN61000-6-2 (EN50082-2), EN61204-3, heavy industry level, criteria A , SEMI F47, GL approved		
	MTBF	112.9Khrs min. MIL-HDBK-217F (25°C)		
OTHERS	DIMENSION	85.5*125.2*128.5mm (W*H*D)		
	PACKING	1.6Kg; 8pcs/13.8Kg/0.9CUFT		
NOTE	Ripple & noise are measure Tolerance: includes set up The power supply is consid EMC directives. Installation clearances: 40r In case the adjacent device	ally mentioned are measured at 230VAC input, rated load and 25°C of ambient temperature. In ally mentioned are measured at 230VAC input, rated load and 25°C of ambient temperature. In all 20MHz of bandwidth by using a 12" twisted pair-wire terminated with a 0.1 uf & 47 uf parallel capacitor. In polerance, line regulation and load regulation. In idered a component which will be installed into a final equipment. The final equipment must be re-confirmed that it still meets In idered a component which will be installed into a final equipment. The final equipment must be re-confirmed that it still meets In idered a component which will be installed into a final equipment. The final equipment must be re-confirmed that it still meets In idered a component which will be installed into a final equipment. The final equipment must be re-confirmed that it still meets In idered a component which will be installed into a final equipment. The final equipment must be re-confirmed that it still meets In idered a component which will be installed into a final equipment. The final equipment must be re-confirmed that it still meets In idered a component which will be installed into a final equipment. The final equipment must be re-confirmed that it still meets In idered a component which will be installed into a final equipment. The final equipment must be re-confirmed that it still meets In identification in identific		

- 6. 3 seconds peak power max. and the average output power should not exceed the rate power.
- 7. Derating may be needed under low input voltage. Please check the derating curve for more details.







